



NORTH ANDOVER WATER TREATMENT PLANT

420 Great Pond Road
North Andover, MA 01845
978-688-9574
978-688-9575 FAX

CONTACTS

Glen Alt
Superintendent

HOURS

Summer: 5:00am to 9:00pm
Winter: 6:00am to 6:30pm
Weekends: 6:00am to 6:00pm

INSIDE THIS ISSUE:

Where Your Drinking
Water Comes From

Source Water Assess-
ment Plan

Lake Cochichewick

The Water Treatment
Process

2015 Sampling Results

Benefits of Fluoridation

Water Facts

2015 Annual Drinking Water Quality Report

NORTH ANDOVER WATER DEPARTMENT

PWS ID #3210000

Quality Matters

Once again we are proud to present our annual water quality report to our residents. This report covers many topics of interest along with the results of tests performed from January 1 to December 31, 2015. Throughout the years, we have dedicated ourselves to producing drinking water that meets and surpasses all state and federal standards. It is always our utmost importance that we are delivering the highest quality drinking water to you. As new challenges to drinking water safety emerge, we remain vigilant in meeting the goals of source water protection, water conservation, and community education while continuing to serve the needs of all our water users. Please share with us your thoughts or concerns about the information in this report. After all, well-informed customers are our best allies.

In our efforts to become more "green" this and all future water quality reports will be available on the Town's website for review and a paper copy will be sent to anyone requesting one. If you would like a printed copy or if you have any questions or comments regarding our report, please email **Glen Alt Superintendent**, at galt@townofnorthandover.com or call at **(978) 688-9574**.

Community Participation

The public is encouraged to participate and make comments on concerns about the town water system. We would also like to invite you to participate in issues concerning your drinking water and source by attending Town Meetings, along with Board of Selectmen, Board of Health and Planning Board meetings. Times, dates and locations are continuously posted on the Town's website at: www.townofnorthandover.com.

Also, please be vigilant while enjoying the lake and report any suspicious activity immediately to the Police Department at (978) 683-3168.

Water Conservation Tips

- Check every faucet in your home for leaks. Just a slow drip can waste 15 to 20 gallons a day. Fix it and you can save almost 6,000 gallons per year.
- Check your toilets by putting in a few drops of food coloring in the tank. If you have a leak the color will show up in the bowl after a few minutes. It is not uncommon to lose up to 100 gallons a day from an invisible toilet leak. Fix it and you save more than 30,000 gallons a year.
- Use your water meter to detect hidden leaks. Simply turn off all taps and water-using appliances. Then check the meter after 15 minutes. If it moved, you have a leak.
- Install water saving shower heads and low-flow faucet aerators
- Insulate your water pipes. You'll get hot water faster plus avoid wasting water while it heats up
- Take shorter showers. A four minute shower use approximately 20—40 gallons of water
- Keep a bottle of drinking water in the fridge. Running tap water to cool it off for drinking water is wasteful. Store drinking water in the fridge in a safe drinking bottle.

Where Your Drinking Water Comes From

With the exception of a scattering of private wells, North Andover's drinking water primarily comes from Lake Cochichewick. It is considered a "surface" source. The lake has a length of 2.65 miles and a width just under 3/4 of a mile with 7.35 miles of shoreline. The maximum water depth of the lake is approximately 45 feet, with an average depth of 23 feet. The watershed, which in essence is an extension of the lake, has an area of approximately 2,732 acres that drains toward the lake from runoff, springs, and brooks. The lake holds approximately 4.3 billion gallons of water.

The treatment plant pumps roughly 1.1 billion gallons of water every year from the lake for the treatment process, fire protection and for the delivery of clean, safe drinking water to the town. We pump on average 3.2 million gallons per day (MGD), with our high average in the summer months of 6.5—7.0 MGD. This dramatic increased stress on our water supply is mostly caused by non-essential water use such as lawn irrigation.

To help with our conservation efforts during the hot summer months try watering your lawns and gardens before 8 AM and after 6PM, check your sprinkler heads for leaks and make sure that you have rain sensors installed to shut down sprinklers during rainy days, and mulch. Using organic mulch around plants could save you hundreds of gallons per year by reducing evaporation.

Lake Cochichewick—Your Drinking Water Reservoir

PERMISSIBLE ACTIVITIES

Passive Recreation: Walking, Hiking, Jogging, and Biking

Fishing: From Shoreline or Boats that are designed to be manually propelled by oars or paddles. Electric motors are acceptable as an alternate form of propulsion. Max length of a motorized craft is 15ft. Must have a valid state license.

Boating: Rowing shells, johnboats, rowboats, canoes and kayaks are acceptable as long as the occupants are isolated from contact with the lake.

DOMESTIC ANIMALS ARE NOT ALLOWED IN CRAFT or ON THE ICE

RESTRICTED ACTIVITIES

(All are fineable offenses)

No Littering. All supplies and debris that is carried in must be carried off.

No Swimming, Bathing, or Wading

No Hip Waders shall be worn—fish from shore or boat only.

No Windsurfers or Paddleboards

No Gasoline/Diesel powered engines for anything that uses fuel such as, but not limited to: boats, snowmobiles, ice augers, stoves, lamps.

No dogs or any other domestic animal allowed in the water for any reason.

***The Town of North Andover has a leash law for all dogs and the open space and recreation areas are NOT exempt**

PROTECT YOUR DRINKING WATER SUPPLY



The North Andover Water Treatment Plant



Ozone generator room

We are proud of the exceptional quality of water that flows to your household or business daily. We treat the water with great care here at the treatment plant to enhance its quality. We are fortunate to have such clean source water. The Water Treatment Plant is a conventional filtration plant, which includes **ozonation**, **coagulation**, **flocculation**, and **sedimentation**. The treatment process consists of a series of physical and chemical steps designed to produce a safe and consistent quality product.

First, untreated water is pumped from Lake Cochichewick into the plant and sent to the **ozone** contact chamber. Ozone gas is generated on-site, and is used as a strong oxidant and disinfectant, breaking down organic matter making the water easier to filter.

From there water enters a mixing chamber where the coagulant, **poly-aluminum chloride** is added to aid in the formation of floc. This processes known as **coagulation** and **flocculation** is needed to make small particles stick together so that they become large enough to settle out during the next process in treatment called **sedimentation**.

The water that is now clearer of the removed particles then flows into the **Carbon Filters**. North Andover has eight deep bed dual granular activated carbon (GAC) and sand filters. These filters remove any remaining impurities. The filtered or "finished" water is then sent to the **clear-well** which holds 620,000 gallons and is located under the plant. To complete purification, **sodium hypochlorite** is added for disinfection to the filter effluent. **Sodium Hydroxide** is also added for pH control adjustment.



Pipe gallery

Fluoride is added to the finished water at about 1ppm to prevent tooth decay and cavities. As a final step, **Zinc Orthophosphate**, a corrosion inhibitor, is added as the water leaves the plant to protect the linings of the distribution system pipes. From there, treated water is pumped into North Andover's water distribution system. The plant is equipped with four finish water pumps, with a pumping capacity of 12 million gallons per day

At that point when water leaves the treatment plant, it is safe, odorless, colorless and tasteless. The water is then pumped through the distribution system to two sanitized 2.2 million gallon in-ground storage tanks and into a one million gallon stand pipe and into your homes and businesses.

To ensure you that we are providing the highest quality of water available, your water system is operated by Massachusetts certified operators who oversee the routine operations of our system. The water quality is constantly monitored by us, in our on-site laboratory, and by the **MassDEP** to determine effectiveness of existing water treatment and to determine if any addition treatment is required.



Filter gallery



Bradford Standpipe, one of three drinking water storage tanks.

2015 Sampling Results

Water Quality Data

During the past year, we have taken hundreds of water samples in order to determine the presence of any radioactive, biological, inorganic, volatile organic or synthetic organic contaminants. The table below shows only those contaminants that were detected in the water. The state requires us to monitor for certain substances less than once per year because the concentrations of these substances do not change frequently. In these cases, the most recent sample data are included, along with the year in which the sample was taken.

2015 Water Quality Data from the North Andover Water Department and Distribution System


SUBSTANCE (UNIT OF MEASURE)	YEAR SAMPLED	MCLG	MCL	AMOUNT DETECTED	RANGE LOW-HIGH	VIOLATION	MAJOR SOURCE
REGULATED SUBSTANCES							
Chlorine (ppm)	2015	4	4	0.56	0.01-1.19	NO	Water additive used to control microbes
Fluoride (ppm)	2015	4	4	1.0	0.58-1.00	NO	Water additive which promotes strong teeth; erosion of natural deposits; discharge from fertilizer and aluminum factories
Haloacetic acids [HAA] (ppb)	2015	N/A	60	7.9	1.2-9.0	NO	Byproduct of drinking water disinfection
Nitrate (ppm)	2015	10	10	0.086	N/A	NO	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
TTHMs[Total Trihalomethanes] (ppb)	2015	N/A	80	29.5	8.4-51	NO	Byproduct of drinking water disinfection
Total Organic Carbon (% removal)	2015	N/A	TT	50	46-56	NO	Naturally present in the environment
Turbidity ¹ (NTU)	2015	N/A	TT	0.12	0.04-.12	NO	Soil runoff
Turbidity (Lowest monthly % of samples meeting limit)	2015	N/A	TT	100%	N/A	NO	Soil runoff

¹Turbidity is a measure of the cloudiness of the water. It is monitored because it is a good indicator of the effectiveness of the filtration system

SUBSTANCE (UNIT OF MEASURE)	YEAR SAMPLED	AL	MCLG	AMOUNT DETECTED (90th %tile)	SITES ABOVE AL/ TOTAL SITES	VIOLATION	MAJOR SOURCE
Copper ² (ppm)	2014	1.3	1.3	0.16	0/30	NO	Corrosion of household plumbing systems; Erosion of natural deposits
Lead ² (ppm)	2014	0.015	0	0.002	0/30	NO	Corrosion of household plumbing systems; Erosion of natural deposits

²The town is only required to test for lead and copper every three years due to the non-existent and extremely low levels found at our taps. Tap water samples were collected for lead and copper analysis throughout the community. Samples are scheduled to be collected the summer of 2017.

Averages of Common Parameters



pH: 7.75

Sodium: 39ppm

Iron: 0.00ppm

Manganese: 0.01ppm

Bacteria: Negative

Hardness: 20-30ppm = 1.2-1.8grains/gallon

(North Andover has soft water)



Definitions

- **90th Percentile:** Out of every 10 homes sampled, 9 were at or below this level.
- **AL (Action Level):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
- **MCL (Maximum Contaminant Level):** The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- **MCLG (Maximum Contaminant Level Goal):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- **MRDL (Maximum Residual Disinfectant Level):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- **MRDLG (Maximum Residual Disinfectant Level Goal):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- **NA:** Not available
- **NTU (Nephelometric Turbidity Units):** Measurement of the clarity, or turbidity, of water. Turbidity in excess of 5 NTU is just noticeable to the average person.
- **ppb (parts per billion):** One part substance per billion parts water (or micrograms per liter).
- **ppm (parts per million):** One part substance per million parts water (or milligrams per liter).
- **TT (Treatment Technique):** A required process intended to reduce the level of a contaminant in drinking water.

Lead in Home Plumbing

How Does Lead Get Into My Water?

Lead enters the water ("leaches") through contact with the plumbing. Lead leaches into water through:

Corrosion of:

- Pipes
- Solder
- Fixtures and Faucets (brass)
- Fittings

The amount of lead in your water also depends on the types and amounts of minerals in the water, how long the water stays in the pipes, the amount of wear in the pipes, the water's acidity and its temperature.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high-quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods and steps you can take to minimize exposure is available from the **Safe Drinking Water Hotline or at www.epa.gov/safewater/lead**.

Benefits of Fluoridation

Water fluoridation prevents tooth decay mainly by providing teeth with frequent contact with low levels of fluoride throughout each day and throughout life. Even today, with other available sources of fluoride, studies show that water fluoridation reduces tooth decay by about 25 percent over a person's lifetime.

Community water fluoridation is not only safe and effective, but it is also cost-saving and the least expensive way to deliver the benefits of fluoride to all residents of a community.

Fluoride is a naturally occurring element in many water supplies in trace amounts. Earlier this year Mass Dep has requested we lower the fluoride optimal level in our system to 0.70 part per million (ppm) to improve oral health in children. Our water system has been providing this treatment since 1975.

One of the most widely respected sources for information regarding fluoridation and fluorides is the American Dental Association. The ADA maintains Fluoride and Fluoridation Web pages at <http://www.ada.org/goto/fluoride>.





Important Health Information

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants may be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. The U.S. EPA/CDC (Centers for Disease Control and Prevention) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the **Safe Drinking Water Hotline at (800) 426-4791 or <http://water.epa.gov/drink/hotline>**.

Substances that Could Be in Our Source Water

To ensure that tap water is safe to drink, the Department of Environmental Protection (DEP) and the U.S. Environmental Protection Agency (U.S. EPA) prescribe regulations limiting the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) and Massachusetts Department of Public Health (DPH) regulations establish limits for contaminants in bottled water, which must provide the same protection for public health. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of these contaminants does not necessarily indicate that the water poses a health risk.


The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Substances that may be present in source water include:



- **Microbial Contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations or wildlife;
- **Inorganic Contaminants**, such as salts and metals, which can be naturally occurring or may result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming;
- **Pesticides and Herbicides**, which may come from a variety of sources, such as agriculture, urban storm water runoff and residential uses;
- **Organic Chemical Contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production and which may also come from gas stations, urban storm water runoff and septic systems;

- **Radioactive Contaminants**, which can be naturally occurring or may be the result of oil and gas production and mining activities.

More information about contaminants and potential health effects can be obtained by calling the **U.S. EPA's Safe Drinking Water Hotline at (800) 426-4791**.



Animal Waste and Water Quality

Animal waste is one of the many sources of pollution that can add up to big problems for water quality and may cause health problems as well. Animal waste contains several types of pollutants that contribute to water quality problems: nutrients, pathogens and naturally toxic material, ammonia. When animal waste ends up in a pond, stream, or more importantly Lake Cochichewick, it decomposes, using up oxygen and releasing its pollutants into the water. During summer months when the water is warm, the combination of low oxygen levels and ammonia can kill fish and other aquatic organisms. The nutrients cause excessive growth of aquatic weeds and algae.

Pathogens the disease causing bacteria and viruses associated with animal waste, can also make water unsafe for human use. If pathogens or the indicator bacteria associated with animal waste are found during water testing Stevens Pond may be closed to swimming and Lake Cochichewick may require expensive means to remedy the issue.

Fortunately, there are some simple practices everyone can do to help prevent pollution by keeping animal waste out of the water. While it may seem easier to ignore the problem of animal waste, remember that you are protecting not only the environment but also your own health.

Keeping Animal Waste Out of Our Water

1. Pick up after your pet. Believe it or not preventing water pollution can be as simple as remembering to bring along a plastic bag when you walk your dog. Dispose of the waste in a trash receptacle. Bagging the waste and leaving it does not constitute as cleaning up after your pet.

2. Don't feed waterfowl. While one of the pleasures of a trip to Steves or Lake Cochichewick has always been taking stale bread to feed the waterfowl, the environmental and health impacts of this activity for both humans and birds can be serious. While ducks, geese, and swans all love bread, it lacks the nutrients and roughage of their natural diet. Feeding these birds bread is similar to feeding a small child a diet of candy and soda; they may love it, but it does them no good and may cause long-term health problems. Feeding waterfowl also tends to cause the birds to gather in numbers higher than can be supported by the natural food supplies. These large flocks of birds also create large quantities of waste and serious water pollution problems.

**THINK PICKING UP
DOG POOP IS
UNPLEASANT?
TRY DRINKING IT.**

Pet waste washes into
our storm drains and pollutes
our streams.



Cross Connections and Backflows

What is a cross connection?


A cross connection is any actual or potential connection between the drinking water lines and potential sources of pollution or contamination such as a piping arrangement or equipment that allows the drinking water to come in contact with non-potable liquids, solids, or gases hazardous to humans in event of a backflow.

What is a backflow?

Backflow is the undesired reverse of the water flow in the drinking water distribution lines. This backward flow of the water can occur when the pressure created by equipment or system such as a boiler or air conditioning system is higher than the water pressure inside the water distribution line (back pressure), or when the pressure in the distribution lines drops due to routine occurrences such as water main breaks or heavy water demand causing the water to flow backward inside the water distribution system (backsiphonage). Backflow is a problem that many water consumers are unaware of, a problem that each and every water customer has a responsibility to help prevent.

Simple steps to prevent cross connection hazards:

- Never submerge a watering hose into a pool, tubs, sink, bucket of soapy water, pet watering containers, drains, or chemicals.
- Always leave an air gap between the hose and the object you are filling.
- Install a hose bib vacuum breaker on every threatened water fixture. These can be found at most hardware stores and are easy to install.



For more information, review the Cross-connection Control Manual from the U.S. EPA's Web site at <http://water.epa.gov/infrastructure/drinkingwater/pws/crossconnectioncontrol/index.cfm>. You can also call the Safe Drinking Water Hotline at (800) 426-4791.

Stormwater = NPDES

Water pollution degrades surface waters making them unsafe for drinking, fishing, swimming, and other activities. As authorized by the Clean Water Act, the **National Pollutant Discharge Elimination System (NPDES)** permit program controls water pollution by regulating “point sources” that discharge pollutants into waters of the United States.

Point sources are often discrete conveyances such as pipes or man-made ditches or drains (catch basins) that direct “stormwater” to a surface source. Stormwater runoff is generated when precipitation from rain and snowmelt events flows over land or impervious surfaces (paved streets, parking lots, and building rooftops), and does not percolate into the ground. As the runoff flows over the land and impervious surfaces it accumulates debris, chemicals, sediment or other pollutants that could adversely affect water quality if the runoff is discharged untreated into our lake or tributaries.

Federal and state laws and regulations require municipalities with a storm drain system to manage and control all stormwater discharges in their towns and they, along with everyone who wants to discharge any type of water with pollutants, must first obtain an NPDES permit to do so.

If you see a suspicious discharge to a body of water or storm drain (catch basin, slotted manhole, etc.), please contact **North Andover's Conservation Commission at (978) 688-9530**.



Stormwater tips:

1. Don't dump anything into storm drains. Dispose of hazardous waste through North Andover's ongoing waste oil collection program and bi-annual hazardous waste collection days.
2. When watering your lawn, don't over water. Water that runs off sidewalks and roadways carries contaminants (oil, grease, and metals) into our storm drain system.
3. Divert runoff from pavement to grassy, planted, or wooded areas of your property.
4. Reduce fertilizer and pesticide use.
5. Sweep up salt and sand on your walkways after snowmelt. Don't hose down driveways or sidewalks.
6. Inspect your vehicles and equipment for leaking and damaged parts.

Source Water Assessment Plan

In 2004, the Department of Environmental Protection (DEP) completed an assessment of all the water supplies in Massachusetts. Out of this assessment, they created a plan for each community called a Source Water Assessment Plan (SWAP). The purpose of this SWAP was to determine the susceptibility of each drinking water source to potential sources of contamination.

According to the SWAP, our water system had a susceptibility rating of **HIGH**, due to reasons such as commercial businesses, residential septic systems, underground fuel storage tanks, a golf course and farm activity, all within our watershed, to name a few. It is important to understand that these susceptibility ratings do not imply poor water quality but rather the supply's potential to become contaminated by activities within the watershed. Protecting our watershed is our first line of defense in protecting our drinking water. The complete SWAP report is available online at www.townofnorthandover.com/water – “Lake & Watershed Information.” For more information, please contact **Julie Greenwood-Giglio at (978) 688 9574**.

Non Compliance to Compliance Notice

The North Andover Water Department was in noncompliance due to failure to submit Bromate, Haloacetic Acid, Trihalomethanes, Bacteriological, and Chlorine/Chloramines water-quality-monitoring results to MassDEP by September 10th, 2015 in violation of Massachusetts Drinking Water Regulation 310 CMR 22.03.



Water Facts

- Water covers 70.9% of the Earth's surface.
- Only 3% of Earth's water is fresh water.
- Only 1% of the fresh water is available for drinking water.
- The human body is 75% water
- Water can dissolve more substances than any other liquid including sulfuric acid.
- More than 25% of bottled water comes from a municipal water supply, the same place that tap water comes from
- Approximately 400 billion gallons of water are used in the United States per day.
- Taking a bath requires up to 70 gallons of water. A five-minute shower uses only 10 to 25 gallons.
- Water is the only substance found on earth naturally in three forms: solid, liquid and gas.

Need Answers?

We encourage you to share your thoughts with us on the information contained in this report. Should you ever have any questions about this report or relating to your drinking water please call the water treatment plant at (978) 688-9574, or you can email us at: water.treatment@townofnorthandover.com. Any questions regarding your water bills please call the DPW at (978) 685-0950.



Residents with Private Wells

For a small fee, the North Andover Water Treatment Plant (WTP) lab is certified to conduct bacterial tests, including tests for E. coli, on your water. Sample bottles and instructions can be obtained from the WTP at 420 Great Pond Road. If you would like to find a private lab that is certified for different parameters, you can find them on the state's Web site at <http://edep.dep.mass.gov/labcert/labcert.aspx>. All questions relating to wells should be directed to the health department at (978) 688-9540.

Information on the Internet

The U.S. EPA Office of Water (www.epa.gov/watrhome) and the Centers for Disease Control and Prevention (www.cdc.gov) Web sites provide a substantial amount of information on many issues relating to water resources, water conservation and public health. Also, the DEP has a Web site (www.mass.gov/dep) that provides complete and current information on water issues in Massachusetts, including valuable information about our watershed.

